

# PROVA DI PORTATA VENTILATORE ASSIALE

## AIRFLOW TEST FOR AXIAL FAN

|                         |   |                              |                  |
|-------------------------|---|------------------------------|------------------|
| <b>Tipo - Type</b>      | <b>Tensione di Prova<br/>Test Voltage</b> | <b>N° Prova<br/>Test No.</b> | <b>N° Progr.</b> |
| <b>VA01-AP70/LL-36A</b> | <b>13 V. CC. - DC.</b>                    | <b>764-03</b>                | <b>2890</b>      |
| <b>Note<br/>Notes</b>   |   |                              |                  |

| <b>Pressione Statica<br/>Static Pressure<br/>mmH2O</b> | <b>Portata<br/>Airflow<br/>m<sup>3</sup>/h</b> | <b>Corrente Assorbita<br/>Current input<br/>A</b> |
|--|--|---|
| 0,0  | 2.830  | 16,5  |
| 2,4  | 2.718  | 17,6  |
| 5,0  | 2.551  | 17,4  |
| 7,6  | 2.399  | 17,7  |
| 10,0   | 2.226  | 17,7  |
| 12,6   | 2.053  | 18,0  |
| 15,1   | 1.779  | 17,9  |
| 17,5   | 1.366  | 17,7  |
| 20,1   | 1.037  | 18,7  |
| 22,4   | 959  | 19,5  |
| 25,0   | 851  | 20,0  |
| 27,5   | 704  | 21,3  |
| 29,9   | 646  | 20,9  |
| 32,6   | 460  | 21,4  |
| 35,0   | 289  | 22,1  |
| 36,9   | 0  | 22,8  |

|             |                         |
|-------------|-------------------------|
| <b>Note</b> | <hr/> <hr/> <hr/> <hr/> |
|-------------|-------------------------|